


Hygiene-Institut des Ruhrgebiets

Institut für Umwelthygiene und Toxikologie

Direktor: Prof. Dr. rer. nat. L. Dunemann

Träger: Verein zur Bekämpfung der Volkskrankheiten im Ruhrkohlengebiet e.V.

Hygiene-Institut, UMWELT Postfach 10 12 55 · 45812 Gelsenkirchen



Rotthauer Str. 21
45879 Gelsenkirchen

Telefon (0209) 9242-0
Telefax (0209) 9242-222
Internet www.hyg.de

Unser Zeichen: W-314772-19-HO
Ansprechpartner: Dipl.-Ing. (FH) S. Horn

Test - certificate

hygiene – conformity check to the design requirements of selected technical guidelines

Test institute:	Hygiene Institut des Ruhrgebiets Institut für Umwelthygiene und Toxikologie Rotthauer Straße 21 49879 Gelsenkirchen
Test object:	Counterflow heat exchanger Swiss Rotors
Manufacturer:	Swiss Rotors Aktiengesellschaft Eichengasse 3 4702 Oensingen Schweiz
Basis of the examination:	✓ VDI 6022, sheet 1 (01/2018) ✓ SWKI VA104-01 (01/2019)
Validity period:	5 years 06/2019 – 06/2024
Test report:	W-314772-19-HO



In conclusion it can be stated that the examined "Counterflow heat exchanger Swiss Rotors" specified in the test report W-314772-19-HO, is in compliance with the design requirements of the above mentioned regulations.

(Priv.-Doz. Dr. G.-J. Tuschewitzki)
Head of the Department of Water
Hygiene and Environmental
Microbiology

(Dipl.-Ing. (FH) S. Horn)
Section head of Air Conditioning technology
Department of Water Hygiene and Environmental
Microbiology

issued 27.06.2019, Gelsenkirchen

Within the framework of the conformity check the hygiene-relevant requirements of the above mentioned regulations was examined. Requirements of other regulations that refer to the above mentioned regulations were not part of the examination. Additionally, the conformity check does not include a toxicological or sensory testing of the introduced materials. This document is not part of a certification process.

Träger: Verein zur Bekämpfung der Volkskrankheiten im Ruhrkohlengebiet e.V., Vereinsregister: VR 519 Amtsgericht Gelsenkirchen, USt.-ID: DE125018356
Vorstand: Prof. Dr. Werner Schlake (Vors.), Prof. Dr. Jürgen Kretschmann, Dr. Emanuel Grün, Dr. Dirk Waider, Prof. Dr. Lothar Dunemann (geschäftsführ. Vorstand)